

Certificate

No. z5413b-19-E

Customer:

EVN electronic Components GmbH
Maybachstraße 39
73037 Göppingen, Germany

Category 6A

Test sample(s):

Connector:

**CAT6A 10G Keystone module, shielded type, toolless assembly,
for cable AWG26/1-AWG22/1, AWG27/7-AWG22/7, POE+ possible,
with Dustcap**

Part-no.: PS-KS-C6A-SZW

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

IEC 60603-7-51 Ed.1.0 (2010-03)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

Connector, Copper, Category 6A

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **P5413b-19-E** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of issue.

Bexbach, 27. March 2019



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



*Test laboratory accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2005.
The accreditation is valid for the test methods listed in certificate D-PL-17559-01-00.*

GHMT AG

In der Kolling 13
66450 Bexbach / Germany

P0 box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**